



Date: January 31, 2024

Airflow Specifications for 8x8 Wall Lite+

Free Area	Face Velocity	400	500	600	700	800	900	1000	1100	1400	1700	2000	2300	2600	2900	3200
	SP	0.01	0.02	0.03	0.04	0.05	0.06	0.07	0.08	0.13	0.19	0.27	0.35	0.44	0.54	0.66
0.169	CFM	38	46	55	63	72	80	89	98	123	149	175	201	227	252	278

Note:

1. Performance Data is based on ASHRAE 70-23.
2. CFM: Standard air density and isothermal conditions.
3. Static Pressure (SP): Inches of water gauge.
4. Face Velocity: Face discharge velocity in feet per minute (fpm).
5. Dashed line [-] in SP box indicates SP is less than 0.01 w.g.
6. Area Factor (Ak): No longer measured or calculated in ASHRAE 70-23.
7. Free Area: Total minimum area in ft² of the openings in the vent through which air is able to pass.